

Addendum No. 03 and Clarification No 02
Issued Date: 28 April 2026

Jagdulla Hydropower Company Limited, Jagdulla PROR Hydroelectric Project (106 MW)
Lot No. 3: Electromechanical Works of Jagdulla PROR Hydroelectric Project under Plant and Design Build Contract, Contract Identification No: JHCL/JHEP/EM/ICB/082-083/PDB-1

Under ITB 8.1 of the Bidding Document for "Lot No. 3: Electromechanical Works of Jagdulla PROR Hydroelectric Project under Plant and Design Build Contract, Contract Identification No: JHCL/JHEP/EM/ICB/082-083/PDB-1," the following amendments have been made: **1. Amendments to IFB**

1. Volume 2 of the Bidding Document

S. No.	Page No.	Reference Clause/ Chapter No.	Clause/Section as Existing	Clause/Section as Amended
Volume 2 of the Bidding Document				
1	547 and 876	Volume 2, Section 4 PTR - Elec. Works, Chapter 2, Clause 2.4.3 d.	d. The coil insulation shall be non-inflammable and be properly vacuum pressure impregnated with high-grade insulation synthetic resin. The insulation shall become reasonably plastic by the application of heat, or shall otherwise be of such nature that the coil can be placed in or moved from the slot without injury.	d. The coil insulation shall be non-inflammable and be properly vacuum pressure impregnated with high-grade insulation synthetic resin type or Mold-Pressed / Cast Resin type. The insulation shall become reasonably plastic by the application of heat or shall otherwise be of such nature that the coil can be placed in or moved from the slot without injury.

For detailed information on Clarification 2, please visit: <https://bolpatra.gov.np/>

